



201512341026

MTT-ZJ-54



MTT2025J180

No: MTT2025J18001



MINGBO TESTING TECHNOLOGY

检测报告

TEST REPORT

项目名称: 2025 年第四季度水质检测

生产单位: /

委托单位: 山东中阳新材料科技股份有限公司


检测类别: 委托

山东铭博检测技术有限公司

Shandong Mingbo Testing Technology Co. LTD



注意事项



1. 报告无“检测专用章”及骑缝章无效。
2. 复制报告未重新加盖“检测专用章”无效。部分复制报告无效。
3. 报告内容需填写齐全，无编制、审核、授权签字人签字无效。
4. 报告中“ND”表示检测结果低于方法检出限。
5. 检测委托方如对检测报告有异议，请在收到本检测报告之日起 15 日内向检测单位提出，逾期不予受理。
6. 采样检测，检测结果仅对本次采样负责；送样检测，检测结果仅对来样负责。
7. 未经同意，不得复制本报告。
8. 未经同意，不得用于广告宣传。
9. 其它需说明的问题：
 - 1) 需要时提出的意见和解释；
 - 2) 客户要求的附加信息。

ATTENTION

1. The report is invalid without the special seal for test or across-page seal.
2. The copy of the report is invalid without being re-stamped. Partial copy report is invalid.
3. The contents of the report need to be completed. The report is invalid without the signatures of persons who prepare, audit and authorized officer.
4. “ND” in this report indicates that the detection result is below the detection limit of the method.
5. If there is any objection concerning the report, please submit to the testing unit within 15 days from the date of receipt of this report. Late objection will not be accepted.
6. Sampling detection, the detection result is only responsible for this sampling; For sample delivery test, the test result is only responsible for incoming samples.
7. This report shall not be duplicated without consent.
8. The report shall not be used for advertising without consent.
9. Other issues to be explained:
 - 1) Comments and explanations when necessary.
 - 2) Additional information requested by customers.

地 址：山东省东营市东营区运河路 336 号光谷未来城 32 幢 101 室

邮政编码：257100

电 话：0546—8338577

传 真：0546—8338577

E-mail: sdmbjsb@163.com



山东铭博检测技术有限公司

检 测 报 告

一、基本信息

项目名称	2025 年第四季度水质检测	任务编号	MTT2025J180
委托单位	山东中阳新材料科技股份有限公司	联系方式	张亮亮 19954300166
样品来源	采样	采样时间	2025.10.16
样品状态	水质：清澈 详见备注	检测时间	2025.10.16
项目地址	山东省东营市利津县中小企业创业园		
检测项目	水质：总有机碳，共 1 项。		
备 注	水质样品数量：10×250ml 棕色玻璃瓶（总有机碳）。		

技
★
测专

二、检测依据及主要仪器

序号	检测项目	检测方法	方法依据	主要仪器设备型号、名称/编号
水质				
1	总有机碳	水质 总有机碳的测定 燃烧氧化-非分散红外吸收法	HJ 501-2009	总有机碳分析仪 TOC-L CPH SSM-5000A/MTT-YQ-A010

三、检测结果

样品类别：水质		检测项目	总有机碳	
		单位	mg/L	
		检出限	0.1	
		采样日期	2025.10.16	
点位名称	采样频次	样品编号	测定值	平均值
生产一部	1	C25J1800101	5.3	5.3
	2	C25J1800102	5.5	
	3	C25J1800103	5.2	
生产二部	1	C25J1800201	13.6	13.6
	2	C25J1800202	13.7	
	3	C25J1800203	13.5	
生产三部	1	C25J1800301	6.8	6.9
	2	C25J1800302	6.9	
	3	C25J1800303	7.0	

本页以下空白。

四、质控信息

- 1、本次对于不同检测项目均采取相应的检测标准及方法。
- 2、本次采样、分析所用仪器全部经计量检定部门检定合格，在有效期内。

五、附件



附图 1 现场照片

采样人员: 邓国柱、苟振双

检测分析人员: 贾延霞

编制人: 董兴菊

日期: 2025.10.21

审核人: 批环

日期: 2025.10.21

授权签字人: 董兴菊

日期: 2025.10.21

山东铭博检测技术有限公司
(检验检测专用章)

报告结束